



(260)-422-8823

OPERATING INSTRUCTIONS FOR MODEL 1550 SECURITY SYSTEM

To clear a mistake:

Press #

To arm the system when no one is staying inside the premises:

Enter the combination

The exit delay permits you to exit the delayed door. The system senses a delayed door was opened/closed and automatically activated the interior detection devices.

To arm the perimeter while at home and later arm the interior:

Enter the combination (activates perimeter)
Press *1 (activates interior devices)

To reset the panic system:

Enter the combination

To reset the fire alarm:

- A) Before 30 seconds have elapsed - put in code to stop siren, check to see which smoke detector went into alarm (red light on solid) and then press *7 (hold the 7 button for about 5 seconds) to reset the detectors.
- B) After 30 seconds have elapsed - press # to stop siren, then press *7 (hold the 7 button for about 5 seconds) to reset detectors, then call 422-8823 to cancel the fire dispatch.

To review an alarm event in memory (memory light on):

Press *3 (the zone or zones violated will blink displaying any violated zones.). Press 9 previous alarms (up to three separate alarm events will be held in memory). Press # to return to normal. The memory light may stay on until the system is armed the next time.

To review a trouble condition (trouble light on and system beeping every 10 seconds):

Press *2 - a zone light will illuminate indicating the type of trouble and then the # key to return to normal.

Zone light	1 - Low battery
	2 - Loss of AC power
	3 - Fuse failure - bell/siren or aux. output
	4 - Unsuccessful communication
	5 - Fire alarm circuit trouble
	6 - Loss of time on internal system clock

To arm the system when someone is staying inside the premises: (bypassing the interior detection device)

Press *1 (zones to be bypassed - ex: 4 for zone 4, 5 for zone 5)
Press # and the combination

SILENT KNIGHT FIRE ALARM

Silence and Reset Fire Alarm

Before 30 seconds have elapsed:

- Enter 4-digit code to stop siren
- Check which motion detector went into alarm (Solid red light)
- Press *7 and hold the 7 button for 5 seconds

To reset detectors

After 30 seconds have elapsed:

- Press # to stop siren
- Press *7 and hold the 7 button for 5 seconds
- Call 260-422-8823 to cancel the fire dispatch